



## TEST REPORT

Report Reference 74293-M18ONEHCCT60CuEL

Issue Date 2022/09/23




This is to certify that representative samples when crimped as specified comply with the connector requirements of UL486A-486B for the tests conducted.

[See Page 3 of this report for Test Combinations]

Representative Samples Compression cable lugs

Compression Connector Manufacturer Elpress

Compression Tool *Milwaukee Tool*<sup>®</sup> Battery-operated Cable Crimper Model M18 ONEHCCT60

Test Conducted by:	Results Reviewed by:	Test Laboratory Manager:
		
Robert Barbian	Denise Schwager	Christopher Ritchie
Team Lead Eng. Test Lab	Sr. Regulatory Engineer	Manager Engineering Lab
Date: 2022/9/15	Date: 2022/09/23	Date: 2022/09/23

## Summary

Milwaukee Tool carried out type tests according to UL 486A-486B on compression connectors manufactured by Elpress.

Testing was completed in Milwaukee Tool’s certified testing laboratory at headquarters in Brookfield, WI.

Test Dates	Test Laboratory	Tests conducted
2022/06/14, 2022/06/15; 2022/06/17, 2022/06/20, 2022/06/24, 2022/06/28 - 2022/06/30; 2022/08/18, 2022/08/19, 2022/08/25	Milwaukee Tool 13135 W. Lisbon Rd. Brookfield, WI 53005	Static-heating Sequence, UL 486A-486B clause 9.3

## Procedure

A summary of the testing methods are as follows:

### Sample Preparation

- Samples of each combination were prepared in accordance to the applicable standard;
- Tool, connector & conductors were prepared according the chart in “Test Combinations”;
- Connectors were crimped according to the manufacturers instructions.

### Testing

- Testing was completed according to UL 486A-486B.

**Test Combinations**


Four samples of each test combination were constructed.

Test	Milwaukee Tool Crimp Tool designation	Elpress Connector designation	Fine Wire Cu Conductor, Class 5 & Class 6	Number of crimps
			nominal cross-sectional area	
Static- heating Sequence	Model M18ONEHCCT60	KRF16-12	16 mm <sup>2</sup>	1
		KRF50-16	50 mm <sup>2</sup>	2
		KRF70-16	70 mm <sup>2</sup>	2
		KRF150-20	150 mm <sup>2</sup>	3
		KRF300A-24	300 mm <sup>2</sup>	4

### Test Setups



**Current-cycling Fixture**



**Secureness Fixture**



**Pullout Fixture**

## Test Conditions

Epress Connector designation	Fine Wire Cu Conductor, Class 5 & Class 6	Secureness	Static-heat	Pullout
	nominal cross-sectional area	Weight, lb	Test Current, A	Force applied, lb
KRF16-12	16 mm <sup>2</sup>	22	105	114
KRF50-16	50 mm <sup>2</sup>	50	219	234.5
KRF70-16	70 mm <sup>2</sup>	51.5	272	307.5
KRF150-20	150 mm <sup>2</sup>	76	442	540
KRF300A-24	300 mm <sup>2</sup>	100	685	892.5

## Results

The results of the testing were considered satisfactory. All connections were intact and no connector temperature exceeded 50°C during the Static-heat test.

## Conclusion

After testing of the compression cable lugs (conductor cross sections 16 mm<sup>2</sup>, 50 mm<sup>2</sup>, 70 mm<sup>2</sup>, 150 mm<sup>2</sup> and 300 mm<sup>2</sup>) we declare that the compression cable lugs comply with the connector requirements as specified in UL 486A-486B clause 9.3.

## Attachment

Connector drawing and installation instructions.

- End of Test Report -