



TEST REPORT

Report Reference 74293-M18ONEHCCT60CuKL

Issue Date 2022/08/04




This is to certify that representative samples when crimped as specified comply with the connector requirements of UL486A-486B for the tests conducted.

[See Page 3 of this report for Test Combinations]

Representative Samples Compression cable lugs, DIN 46235

Compression Connector Manufacturer Gustav Klauke GmbH

Compression Tool *Milwaukee Tool*[®] Battery-operated Cable Crimper Model M18 ONEHCCT60

Test Conducted by:	Results Reviewed by:	Test Laboratory Manager:
		
Robert Barbian	Denise Schwager	Christopher Ritchie
Team Lead Eng. Test Lab	Sr. Regulatory Engineer	Manager Engineering Lab
Date: 2022/08/04	Date: 2022/08/05	Date: 2022/08/05

Summary

Milwaukee Tool carried out type tests according to UL 486A-486B on compression connectors manufactured by Gustav Klauke GmbH.

Testing was completed in Milwaukee Tool's certified testing laboratory at headquarters in Brookfield, WI.

Test Dates	Test Laboratory	Tests conducted
2021/09/10; 2021/09/15 - 2021/09/17; 2021/09/21; 2021/10/06; 2021/10/07; 2021/10/13; 2021/10/15	Milwaukee Tool 13135 W. Lisbon Rd. Brookfield, WI 53005	Static-heating Sequence, UL 486A-486B clause 9.3

Procedure

A summary of the testing methods are as follows:

Sample Preparation

- Samples of each combination were prepared in accordance to the applicable standard;
- Tool, connector & conductors were prepared according the chart in "Test Combinations";
- Connectors were crimped according to the manufacturers instructions.

Testing

- Testing was completed according to UL 486A-486B.

Test Combinations


Four samples of each test combination were constructed.

Test	Milwaukee Tool Crimp Tool designation	Klauke Connector designation	Klauke Sleeve designation	Fine Wire Cu Conductor, Class 5 & Class 6	Number of crimps
				nominal cross-sectional area	
Static-heating Sequence	Model M18ONEHCCT60	101R8	N/A	6 mm ²	2
		106R16	VHD50	50 mm ²	3
		110R20	VHD150	150 mm ²	4
		113R20	VHD300	300 mm ²	5

Test Setups



Current-cycling Fixture



Secureness Fixture



Pullout Fixture

Test Conditions

Klauke Connector designation	Fine Wire Cu Conductor, Class 5 & Class 6	Secureness	Static-heat	Pullout
	nominal cross-sectional area	Weight, lb	Test Current, A	Force applied, lb
101R8	6 mm ²	5.75	54.7	82
106R16	50 mm ²	50	219	234.5
110R20	150 mm ²	76	442	540
113R20	300 mm ²	100	685	892.5

Results

The results of the testing were considered satisfactory. All connections were intact and no connector temperature exceeded 50°C during the Static-heat test.

Conclusion

After testing of the compression cable lugs (conductor cross sections 6 mm², 50 mm², 150 mm² and 300 mm²) we declare that the compression cable lugs comply with the connector requirements as specified in UL 486A-486B clause 9.3.

Attachments

Connector drawing and manufacturers published installation instructions.

- End of Test Report -